
Racks with P3-RX Modules

Remote Slave Module

P3-RX \$499.00

The P3-RX is a high-performance Remote Slave module for use with P3-550E CPU-based systems. It has several communications ports which support USB Expansion I/O, Ethernet Remote I/O and serial devices.


Up to 16 Remote Slaves can be connected to a single CPU for a remote I/O network.



Rack with CPU Module

(P3-550E)

Add up to 4 bases to each group using P3-EX expansion modules with USB connections.



Remote Slave Specifications (for P3-550E)		
Mounting Location Controller slot		
Display	No LCD display	
Communications	USB IN: N/A REMOTE I/O: (10/100 Mbps Ethernet) 1 EXP I/O OUT: (2.0, Type A, Proprietary) 4 P3-EX Local Expansion Bases RS-232: (RJ12, 1200–115.2k bps) ASCII, Modbus RS-485: (Removable Terminal Included, 1200–115.2k baud) ASCII, Modbus	
Max. Number of Ethernet Remote I/O Bases	16	
Max. Number of Expansion I/O Bases	68 (4 per CPU, 4 per Remote Base)	
Max. Number of I/O per CPU System	59,840 (CPU Base with 4 Expansion Bases plus 16 Remote Bases with 4 Expansion Bases per Remote, with 11 64-point I/O modules per base)	

P3-RX Product	
Remote I/O Module	P3-RX
LCD Display	N/A
USB Prog/Mon Port	N/A
Remote Port (in)	
USB Local Expansion Port	8
RS-232 RJ12 Port	8
RS-485 Port	8

	General Specifications	
Operating Temperature	0°C-60°C (32°F-140°F)	
Storage Temperature	-20°C-70°C (-4°F-158°F)	
Humidity	5 to 95% (non-condensing)	
Environmental Air	No corrosive gases permitted	
Vibration	IEC60068-2-6 (Test Fc)	
Shock	IEC60068-2-27 (Test Ea)	
Heat Dissipation 4W		
Enclosure Type Open equipment		
Module Location	Controller slot in a remote base in a Productivity3000 system	
Weight	260g (9 oz)	
Agency Approvals	UL508 file E157382, Canada & USA UL1604 file E200031, Canada & USA CE (EN61131-2*) This equipment is suitable for use in Class 1, Division 2, Groups A, B, C and D or non-hazardous locations only.	

^{*}Meets EMC and Safety requirements. See the Declaration of Conformity for details.

WARNING!: EXPLOSION HAZARD – SUBSTITUTION OF COMPONENTS MAY IMPAIR SUITABILITY FOR CLASS I, DIVISION 2.

IMPORTANT!



Hot-Swapping Information


Note: This device cannot be Hot Swapped.

Note: This device cannot be Hot Swapped.



NOTE: When using the P3-RX, you must use Productivity3000® software version 1.0.7.XX and firmware version 1.1.13.XX or later.

Front Panel



Status Indicators

	RX Status Indicators		
PWR Green LED is backlit when power is on			
RUN	Green LED is backlit when CPU has valid project file with RS configured.		
СРИ	Red LED is backlit during power on reset, power down, or watch-dog time-out.		

PWR RUN CPU

Setting the Remote Slave Address

Each Remote Slave must have a unique address between 1 and 99. The address is set using the two rotary switches located on the face of the module, X10 for setting the tens units and X1 for setting the ones unit.


For example, to set a remote slave address to 21, turn the X10 arrow until it points at number 2 and the X1 arrow until it points at number 1.


IMPORTANT NOTES:

- The factory setting of 00 is not a valid address.
- Address selection must be set prior to power-up.
- Slave addresses are only read on power-up.
- If there are duplicate slave addresses on the same network, a critical error will occur.

It is also necessary to configure the remote addresses using the Productivity Suite Programming Software.


This can be done automatically by first going online with a Productivity3000 system that has slave modules installed, go to Hardware Configuration and select the Read Configuration (1) button. The CPU will automatically read the addresses of the remote slaves and add them to the configuration.






Port Specifications

The <u>P3-RX</u> has several communications ports. The following pages have specifications and pin-out diagrams for these ports.




	Remote I/O Port Specifications		
Description	Proprietary transformer isolated Ethernet Port with built-in surge protection for connection to CPU Remote I/O Master port.		
Transfer Rate	10/100 Mbps		
Port Status LEDs	Green LED is illuminated when network LINK is established. Yellow LED backlit when port is active (ACT).		
Cables	Use a Patch (straight-through) cable when a switch or hub is used. Use a Crossover cable when a switch or hub is not used. (Cables available at automationdirect.com)		



EXP I/O OUT Port

USB 2.0 (Type A) Master output for connection to up to four $\underline{\text{P3-EX}}$ local expansion bases, with built-in surge protection.

EXP I/O OUT Specifications		
Description	Proprietary USB 2.0 (Type A) Master output for connection with up of our P3-RX local expansion bases, with built-in surge protection.	
Transfer Rate	480 Mbps	
Port Status LED	Green LED is illuminated when LINK is established to connected device	
Cables	USB Type A to USB Type B. The <u>P3-EX</u> Expansion Module includes a 6 foot USB cable, part number <u>P3-EX-CBL6</u> .	





Mating face of USB type A female

Pin#	Signal
1	Reset
2	– Data
3	+ Data
4	GND

RS-232 Serial Port

Non-isolated RS-232 DTE port connects the <u>P3-RX</u> as a Modbus or ASCII master or slave to a peripheral device.

RS-232 Specifications		
Description	Non-isolated RS-232 DTE port connects the <u>P3-RX</u> as a Modbus or ASCII master or slave to a peripheral device. Includes ESD and built-in surge protection.	
Data Rates	Selectable,1200, 2400, 9600, 19200, 33600, 38400, 57600, and 115200 baud.	
+5V Cable Power Source	210mA maximum at 5V, ±5%. Limited by self-resetting current limiting device. Reverse polarity protected.	
TXD	RS-232 Transmit output	
RXD	RS-232 Receive input	
RTS	Handshaking output for modem control.	
GND	Logic ground	
Maximum Output Load (TXD/RTS)	3kV, 1,000pf	
Minimum Output Voltage Swing	±5V	
Output Short Circuit Protection	±15mA	
Port Status LED	Green LED is illuminated when active for TXD, RXD and RTS	
Cable Options	FA-ISOCON for converting RS-232 to isolated RS-485	



6-pin RJ12 Female Modular Connector

Pin#		Signal
1	GND	Logic Ground
2	+5V	210 mA Maximum
3	RXD	RS-232 Input
4	TXD	RS-232 Output
5	RTS	Request to Send
6	GND	Logic Ground

RS-485 Serial Port

Non-isolated RS-485 port connects the <u>P3-RX</u> as a Modbus or ASCII master or slave to a peripheral device.(Removable connector included.)

	RS-485 Specifications		
Description	Non-isolated RS-485 port connects the <u>P3-RX</u> as a Modbus or ASCII master or slave to a peripheral device. Includes ESD/EFT protection and automatic echo cancellation when transmitter is active.		
Data Rates	Selectable, 1200, 2400, 9600, 19200, 33600, 38400, 57600, and 115200 bps.		
TXD+/RXD+	RS-485 transceiver high		
TXD-/RXD-	RS-485 transceiver low		
GND	Logic ground		
Input Impedance	19kΩ		
Maximum load	50 transceivers, 19kΩ each, 60Ω termination		
Output Short Circuit Protection	±250mA, thermal shut-down protection		
Electrostatic Discharge Protection	±8kΩ per IEC1000-4-2		
Electrical Fast Transient Protection	±2kΩ per IEC1000-4-4.		
Minimum Differential Output Voltage	1.5 V with 60Ω load		
Fail safe inputs	Logic high input state if inputs are unconnected		
Maximum Common Mode Voltage	-7.5 V to 12.5 V.		
Port Status LED	Green LED is illuminated when active for TXD and RXD		
Cable Options	Q8302-1 (cut to length) or Belden 9841 equivalent		








Pin#	Signal
G	GND
_	TXD-/RXD-
+	TXD+/RXD+

*Removable connector included.

Terminal Block Specifications		
Number of Positions	3	
Pitch	5mm	
Wire Range	28–12 AWG Solid Conductor 30–12 AWG Stranded Conductor	
Screw Driver Width	1/8 inch (3.175 mm) maximum	
Screw Size	M2.5	
Screw Torque	4.5 lb·in (0.51 N·m)	

Installation Procedure



Step One:

Locate the two sockets next to the power supply; the module will be inserted into this location.



Step Two:

Insert <u>P3-RX</u> at a 45 angle into the notch located at the top of the base and rotate down until seated.

Step Three:

Snap retaining tab into the locked position.

WARNING: EXPLOSION HAZARD – DO NOT CONNECT OR DISCONNECT CONNECTORS OR OPERATE SWITCHES WHILE CIRCUIT IS LIVE UNLESS THE AREA IS KNOWN TO BE NON-HAZARDOUS. DO NOT HOT SWAP.