





SECTION B-B





SECTION A-A



SPECIAL REQUIREMENTS

BONDED WINDOWS

1. ROUTE COVER FACE DOWN AND REMOVE THE TWO MOUNTING BOSS' WHEN REQUIRED.

2. ROUGH BOTH SURFACES BEFORE BONDING.MINIMUM OVERLAP BETWEEN THE WINDOW AND THE ENCLOSURE IS 0.312".ACRYLIC NEEDS TO BE A MINIMUM 0.125" THICKNESS FOR OPENING SIZES UP TO 14-3/8" X 18-3/8" AND A MINIMUM 0.375" THICKNESS FOR OPENING SIZES LARGER THAN 14-3/8" X 18-3/8" UP TO 31-3/8" X 44-3/8".WINDOW MATERIAL THICKNESS MAY FLUCTUATE ACCORDING TO MANUFACTURE SPECIFIED TOLERANCES:

   SAR/CLASS B: [0.125"+.020 & -.030] [0.375"+.030 & -.060].
   ACRYLITE A/2: NOMINAL SIZE 0.354"+/-.018

UL FILE #E64358,VOL.1,SEC.GEN TYPE RATINGS 1,3R,4X,12.

STAHLIN N SERIES ENCLOSURE, NEMA 1/3/3R/4X/12, 24 X 20 X 8IN (HXWXD), WALL MOUNT, FIBERGLASS REINFORCED POLYESTER, GRAY, SINGLE-DOOR, (4) TWIST-LOCK LATCHES, PADLOCK HASP AND STAPLE, SAR ACRYLIC WINDOW.

NW24208HWT

AutomationDirect.com
1-800-633-0405

3rd ANGLE	NOT TO SCALE	PART DIMENSIONS MAY DIFFER SLIGHTLY DUE TO MANUFACTURER'S VARIANCES	METRIC UNITS USED FOR PART DESIGN	UNLESS OTHERWISE SPECIFIED UNITS ARE:	inch [mm]	LATEST VERSION 1/27/2023	SHEET 1 OF 1