# BALLUFF

# BNI IOL-717-002-E023 BNI IOL-725-002-E023 BNI IOL-730-002-E023 BNI IOL-740-002-E023 User's Guide



### Contents

1	Notes for the user	3
	1.1. Structure of the auide	3
	1.2. Typographical Conventions	3
	Fourmerations	3
	Actions	3
	Suntay	3
	Grass references	3
		ວ າ
	1.3. Symbols	3
	1.4. Abbreviations	3
	1.5. Differing views	3
2	Safaty	4
2	Salety	4
	2.1. Interface use	4
	2.2. Installation and startup	4
	2.3. General safety notes	4
	2.4. Resistance to Aggressive Substances	4
	Hazardous voltage	4
3	Getting Started	5
Ŭ	3.1 Connection overview	5
	2.2 Electrical connection	5
	3.2. Electrical connection	0
		0
		0
		6
	Module versions	6
	3.3. Functionality	1
	3.4. Sensor Interface	8
	3.5. Input signal range	11
	3.6. Output signal range	11
	3.7. Data formats	11
	3.8. Signed data format	12
	3.9. Unsigned data format	13
	3.10. Dimensioned data format	15
4	IO-Link Interface	17
	4.1. IO-Link Data	17
	4.2. Prozess data / Input data	18
	BNI IOL-717-002-E023 / BNI IOL-730-002-E023 / BNI IOL-740-002-E023	18
	4.3. Prozess data / Output data	18
	BNI IOL-725-002-E023 / BNI IOL-730-002-E023	18
	4.4. Parameter data / Request data	19
	Device Temperature	21
	52hex	21
	Setting the serial number 54hex	21
	Operating hours	21
	57hex	21
	Boot counter	21
	58hex	21
	Process data alignment 59hex	22
	Analog mode F0hex	22
	Resolution F1hex	24
	Pin assignment E2hex	24
	Pt100/Pt1000 mode F3bex	24
	Drocess data format E5bay	20
	Switch point 1 Effect Switch point 2 E7box	20
	Switch point 1, 1 Onex Switch point 2, 1 / Nex	20
	Thermoscupic grounding E0hox	20
	Fruit state subsute	26
	Fault state outputs	26

FAhex	26
4.5. Error	27
4.6. Events	27
5 Technical Data	28
5.1. Dimensions	28
5.2. Mechanical Data	28
5.3. Electrical Data	28
5.4. Operating conditions	28
5.5. LED indicators	29
Status LEDs	29
6 Appendix	30
6.1. Type designation code	30
6.2. Order information	30

### 1 Notes for the user

1.1.	Structure of the guide	The guide is organized so that the sections build on one another: Section 2: Basic safety information. Section 3: The main steps for installing the device.
1.2.	Typographical Conventions	The following typographical conventions are used in this guide.
	Enumerations	Enumerations are shown in list form with a dash. - Entry 1, - Entry 2.
	Actions	Action instructions are indicated by a preceding triangle. The result of an action is indicated by an arrow.
	Syntax	<b>Numbers:</b> Decimal numbers are shown without additional indicators (e.g. 123), Hexadecimal numbers are shown with the additional indicator hex (e.g. 00hex).
	Cross references	Cross references indicate where additional information on the topic can be found.
1.3.	Symbols	Attention! This symbol indicates a security notice which must be observed.
		Note This symbol indicates general notes.
1.4.	Abbreviations	BNIBalluff Network InterfaceDPPDirect Parameter PageEMCElectromagnetic CompatibilityFEFunction EarthIOLIO-LinkISDUIndex Service Data UnitMSBMost significant bit
1.5.	Differing views	Product views and images in this manual may differ from the product described. They are intended to serve only as illustrations.

### 2 Safety

2.1.	Intended use	This guide describes the Balluff Network Interface family BNI IOL-7xx-002-E023 for the application as peripheral analog input module to establish connection of analog sensors, RTDs and thermocouple sensors and/or analog output modules. Hereby it is about an IO-Link device which communicates by means of IO-Link protocol with the superordinate IO-Link master assembly.		
2.2.	Installation and startup		Attention! Installation and startup are to be performed only by trained specialists. Qualified bersonnel are persons who are familiar with the installation and operation of the product, and who fulfills the qualifications required for this activity. Any damage resulting from unauthorized manipulation or improper use voids the manufacturer's guarantee and warranty. The Operator is responsible for ensuring that applicable of safety and accident prevention regulations are complied with.	
2.3.	General safety notes	<ul> <li>Commissioning and inspection Before commissioning, carefully read the operating manual. The system must not be used in applications in which the safety of persons is dependent on the function of the device. Authorized Personnel Installation and commissioning may only be performed by trained specialist personnel. Intended use Warranty and liability claims against the manufacturer are rendered void by: <ul> <li>Unauthorized tampering</li> <li>Improper use</li> <li>Use, installation or handling contrary to the instructions provided in this operating manual</li> </ul> </li> <li>Obligations of the Operating Company The device is a piece of equipment from EMC Class A. Such equipment may generate RF noise. The operator must take appropriate precautionary measures. The device may only be used with an approved power supply. Only approved cables may be used. Malfunctions In the event of defects and device malfunctions that cannot be rectified, the device must be taken out of operation and protected against unauthorized use.</li> </ul>		
2.4.	Resistance to Aggressive Substances		Attention! The BNI modules always have good chemical and oil resistance. When used in aggressive media (such as chemicals, oils, lubricants and coolants, each in a high concentration (i.e. too little water content)), the material must first be checked for resistance in the particular application. No defect claims may be asserted in the event of a failure or damage to the BNI modules caused by such aggressive media.	
	Hazardous voltage		Attention! Disconnect all power before servicing equipment.	
		i	<b>Note</b> In the interest of product improvement, the Balluff GmbH reserves the right to change the specifications of the product and the contents of this manual at any time without notice.	

3.1. Connection overview



Fig. 3-1: BNI IOL-7xx-002-E023

- IO-Link interface
   Status LED: IO-Link communication
- 3 Analog connector4 Status LED: Power supply

3.2.	Electrical connection	The BNI IOL-7xx-002 is provided through the through th	2-E023 mc he IO-Link	odules require no separate supply voltage connection. Power interface by the host IO-Link Master.
	IO-Link Interface	IO-Link (M12, A-code	ed, male)	
		2	Pin	Function
		(• Y	1	Power supply controller US, +24V
		3(● ●)1	2	Power supply outputs UA, +24V*
			3	GND, reference potential
		4	4	C/Q, IO-Link data transmission channel
		*only in case	e of variar	nts, with analog output
	Connecting the	Connection	protection	ground to the housing of the Analog converter.
	Analog converter	<ul> <li>Connect the</li> </ul>	incoming	IO-Link line to the Analog converter.
		Note A standard master.	3 or 4 wire	e sensor cable is used for connection to the host IO-Link
	Function ground			
		Note The housing ground and	g of the BN it must be	NI IOL-7xx-002-E023 must be connected to the protection low-impedance and kept as short as possible.
	Module versions	Version		Analog function
		BNI IOL-717-002-	-E023	Input (voltage, current, Pt100 and Pt1000)
				Outout

BNILIOL_717_002_E023		input
	BINI 10E-1 11-002-2023	(voltage, current, Pt100 and Pt1000)
	PNILIOI 725 002 E022	Output
	BNI 10E-123-002-E023	(voltage, current)
	RNI 101 720 002 E022	Input, Output, Temperature
	BINI IOL-730-002-E023	(voltage, current, thermocouple TypJ, TypK, Pt100, Pt1000)
	BNI IOL-740-002-E023	Temperature (thermocouple TypJ, TypK, Pt100, Pt1000)

**3.3. Functionality** The BNI IOL-7xx-002-E023 module has an analog port. The ports can be configured to accept voltage signal, current signal, Pt sensor or thermocouples, depending on the version. Some version has an analog voltage/current output.

Analog port type	Nominal range
Voltage	0 V - 10 V
Voltage	5 V - 10 V
Voltage	-10 V - +10 V
Voltage	0 V – 5 V
Voltage	-5 V - +5 V
Current	4 – 20 mA
Current	0 – 20 mA
Pt100	-200 °C - +850 °C
Pt1000	-200 °C - +850 °C
Typ J	-100 °C - +1200 °C
Тур К	-180 °C - +1370 °C

In case of voltage/current type sensor the input pin of the analog port can be configured. The analog input signal can be connected either to pin2 or pin4. In this case the input/output is a voltage or current input/output, the BNI IOL-7xx-002-E023 has a +24V power supply output, in order to power the connected sensor or actuator.

In case of RTD sensor (Pt100, Pt1000), the sensor can be connected with 2 wire, 3 wire or 4 wire method.

### 3.4. Sensor Interface

Analog port (M12, A-coded, female)



Pin	Voltage / Current input
1	+24 V, 200 mA (sensor supply)
2	Voltage / current input
3	GND (sensor supply, measurement)
4	Voltage / current input
5	-

Pin	Voltage / Current output
1	+24 V, 1.4 A (actor supply)
2	Voltage / current output*
3	GND (sensor supply)
4	Voltage / current output*
5	-

Pin	Pt100, Pt1000 2 wire
1	Current Source 1 - / Analog In -
2	Current Source 1 - / Analog In -
3	-
4	Current Source 1 + / Analog In +
5	-

Pin	Pt100, Pt1000 3 wire
1	Current Source -
2	Current Source 2 + / Analog In -
3	-
4	Current Source 1 + / Analog In +
5	-

Pin	Pt100, Pt1000 4 wire
1	Current Source -
2	Analog In -
3	Analog In +
4	Current Source +
5	-

Pin	Thermocouple Typ J, Typ K
1	-
2	Thermocouple +
3	Thermocouple -
4	-
5	-

\* In case of voltage/current output the output signal appears between pin2 and pin4. The polarity of the output signal depends on the pin assignment configuration. For further description please see IO-Link interface description.

### Note Pin 1 is the supply voltage output for the connected sensor/actuator. Depending on the direction, the pin1 supply voltage can be loaded with 200 mA (input • configuration) or 1.4A (output configuration). In case of input configuration the Pin1 of the IO-Link port is the source of the +24V supply on analog port. In case of output configuration, the Pin2 of the IO-Link port is the source of the +24V supply on analog port. Attention! The +24V on Pin1 is short circuit protected in case of BNI IOL-717-002-E023 and BNI IOL-730-002-E023. In case of BNI IOL-725-002-E023 the Pin1 of the analog port is directly connected to the Pin2 of the IO-Link port. There is no short circuit protection in this case. In case the module is connected to an IO-Link master, the master should have short circuit protection on pin2. **Commissioning Note:** The device must be configured for the required function, before connecting to the sensor interface.





i

### Note

The analog signals shall be connected with a shielded cable to the BNI IOL-7xx-002-E023. The BNI IOL-7xx-002-E023 should be placed as close to the source of the analog signal as possible. The length of the cable with analog signals should not exceed the 3 meter.

### Note

In order to achieve better accuracy in case of thermocouple measurement, the thermocouple should be connected to the device with a special M12 connector for thermocouples (Typ J or Typ K, depending on the thermocouple.).

**3.5. Input signal range** The BNI IOL-7xx-002-E023 supports many standard input signal ranges. In some cases an analog sensor has higher linear output range than the nominal output range. For example a sensor with a 0 - 10 V output can source voltages between -0.5V and 10.5V, and indicates error with a signal <-0.5V or >10.5V. Therefore the BNI IOL-7xx-002-E023 has the following input ranges for the different analog modes.

Analog mode	V <sub>min</sub> [V]	V <sub>max</sub> [V]
0 V – 10 V	-0.5	10.5
5 V – 10 V	4.5	10.5
-10 V – 10 V	-10.5	10.5
0 V – 5 V	-0.5	5.5
-5 V – 5 V	-5.5	5.5

Analog mode	I <sub>min</sub> [mA]	I <sub>max</sub> [mA]
4 mA – 20 mA	3.8	20.5
0 mA – 20 mA	0	20.5

Analog mode	T <sub>min</sub> [°C]	T <sub>max</sub> [°C]
Pt100	-200	850
Pt1000	-200	850
Typ J (ungrounded)	-100	1200
Typ J (grounded)	-100	400
Typ K (ungrounded)	-180	1370
Typ K (grounded)	-100	400

**3.6. Output signal** range The variants with analog outputs (BNI IOL-725-002-E023, BNI IOL-730-002-E023) supports the same output voltage ranges as the inputs, but the output voltage/current range is the same as the nominal range.

0 mA – 20 mA

Analog mode	V <sub>min</sub> [V]	V <sub>max</sub> [V]			
0 V – 10 V	0	10			
5 V – 10 V	5	10			
-10 V – 10 V	-10	10			
0 V – 5 V	0	5			
-5 V – 5 V	-5	0			
Analog mode	I <sub>min</sub> [mA]	Imax [mA]			
4 mA – 20 mA	4	20			

0

### 3.7. Data formats The

**s** The signal on the analog port of the BNI IOL-7xx-002-E023 (input or output signal) will be represented as a digitalized value and sent as a process data over IO-Link. The digitalized value can be represented in different formats (signed, unsigned or dimensioned), in different resolution (16, 14, 12 or 10 bit), with different alignment (left or right aligned).

20

**3.8. Signed data** format In case of signed data format, the digital value is represented in a two's complement format (15 bit + sign, 13 bit + sign, 11 bit + sign, 9 bit + sign depending on the resolution.).

For different configurations, the analog signal (voltage, current, temperature) can be calculated with the following formulas.

Voltage signal (0V-10V, -10V - +10V, 0V - 5V, -5V - +5V):

In case of positive numbers (MSB = 0): Voltage [V] = PortValue  $*\frac{V_{max}}{2^{(N-1)} - 1}$ 

In case of negative numbers (MSB = 1): Voltage [V] = (PortValue  $-2^{N}$ ) \*  $\frac{V_{max}}{2^{(N-1)}-1}$ 

### Voltage signal (5V - 10V):

Input voltage [V] = PortValue  $* \frac{V_{max} - V_{min}}{2^{(N-1)} - 1} + V_{min}$ 

Current signal (0-20mA, 4-20mA):

 $Current [mA] = PortValue * \frac{I_{max} - I_{min}}{2^{(N-1)} - 1} + I_{min}$ 

### Pt100, Pt1000, Typ J, Typ K:

In case of positive numbers (MSB = 0): Temperature [°C] = PortValue  $* \frac{T_{max}}{2^{(N-1)} - 1}$ 

In case of negative numbers (MSB = 1): Temperature [°C] = (PortValue  $-2^{N}$ ) \*  $\frac{T_{max}}{2^{(N-1)}-1}$ 

Where:

PortValue is the digitalized value of the input signal. N is the resolution in bits.  $V_{max}$ ,  $I_{max}$ ,  $T_{max}$  are the higher limits of the selected input range.  $V_{min}$ ,  $I_{min}$ ,  $T_{min}$  are the lower limits of the selected input range.

### Example 1:

The analog mode is set to 0-10V input. The resolution is 14 bit. The process data is right aligned. The digitalized value read over IO-Link is  $1234_{hex} = 4660$ .

The most significant bit of  $1234_{\text{hex}}$  is 0, so it is a positive number. In this case the voltage can be calculated with the following formula:

Input voltage [V] = PortValue \* 
$$\frac{V_{max}}{2^{(N-1)} - 1} = 4660 * \frac{10.5V}{2^{(14-1)} - 1} = 5,974V$$

### Example 2:

The analog mode is set to -10V - +10V input. The resolution is 12 bit. The process data is left aligned. The digitalized value read over IO-Link is ABCO<sub>nex</sub>

The 12 bit value is left aligned, so the 16 bit value read over IO-Link must be shifted right by four (the 12 bit value is  $ABC_{hex}$ ). The most significant bit of the 12 bit value is 1, so it represents a negative number, therefore the voltage can be calculated with the following formula:

Input voltage [V] = (PortValue  $-2^{N}$ ) \*  $\frac{V_{max}}{2^{(N-1)}-1}$  = (ABC<sub>hex</sub>  $-2^{12}$ ) \*  $\frac{10.5V}{2^{(12-1)}-1}$  = -6.915 V

### Example 3:

The analog mode is set to 4-20 mA output The resolution is 16 bit. The digital value written over IO-Link is  $4000_{\text{hex}}$ = 16384 The most significant bit of 3FFF<sub>hex</sub> is 0, so it is a positive number. In this case the voltage can be calculated with the following formula:

Output current 
$$[mA] = \text{PortValue} * \frac{I_{\text{max}} - I_{min}}{2^{(N-1)} - 1} + I_{min} = 16384 * \frac{20mA - 4mA}{2^{(16-1)} - 1} + 4mA = 12mA$$

3.9. Unsigned data format In case of unsigned data format, the analog signal will be represented as a number between 0000<sub>hex</sub> and the full scale value according to the resolution (FFFF<sub>hex</sub> in case of 16 bit resolution). The analog signal of the BNI IOL-7xx-002-E032 can be calculated from the digital value with the following formulas:

Voltage signal (0V-10V, 5V - 10V, -10V - +10V, 0V - 5V, -5V - +5V):

Voltage [V] = PortValue \* 
$$\frac{V_{max} - V_{min}}{2^{N} - 1} + V_{min}$$

### Current signal (0-20mA, 4-20mA):

Current [mA] = PortValue \*  $\frac{I_{max} - I_{min}}{2^{N} - 1} + I_{min}$ 

### Pt100, Pt1000, Typ J, Typ K:

$$\label{eq:Temperature} \text{Temperature} \left[ ^{\circ}\text{C} \right] = \text{PortValue} * \frac{\text{T}_{\text{max}} - \text{T}_{\text{min}}}{2^{N} - 1} + \ \text{T}_{\text{min}}$$

Where:

PortValue is the digitalized value of the input signal. N is the resolution in bits.  $V_{max}$ ,  $I_{max}$ ,  $T_{max}$  are the higher limits of the selected input range.  $V_{min}$ ,  $I_{min}$ ,  $T_{min}$  are the lower limits of the selected input range.

### Example 1:

The analog mode is set to 0-10V input. The resolution is 14 bit. The process data is right aligned. The digitalized value read over IO-Link is  $2345_{hex} = 9029$ .

In case of 0-10V, the analog input voltage range is between -0.5V and 10.5V. Therefore  $V_{\text{min}}$  = -0.5V,  $V_{\text{max}}$ =10.5V.

Input voltage [V] = PortValue \* 
$$\frac{V_{max} - V_{min}}{2^N - 1} + V_{min} = 9029 * \frac{10.5V - (-0.5V)}{2^{14} - 1} + (-0.5V) = 5.562V$$

### Example 2:

The analog mode is set to 4-20 mA input. The resolution is 12 bit. The process data is left aligned. The digitalized value read over IO-Link is ABCO<sub>nex</sub>

In case of 4-20 mA, the analog input current range is between 3.8 mA and 20.5 mA. The digitalized value is read over IO-Link as a 16 bit value, but the resolution is 12 bit and it is left aligned, so the 12 bit digitalized data is  $ABC_{hex} = 2748$ .

Input current [mA] = PortValue \*  $\frac{I_{max} - I_{min}}{2^N - 1} + I_{min} = 2748 * \frac{20.5mA - 3.8mA}{2^{12} - 1} + 3.8mA = 15.007mA$ 

### Example 3:

The analog mode is set to TypJ Thermocouple. The resolution is 16 bit The digitalized value read over IO-Link is 4567hex = 17767

Temperature [°C] = PortValue \*  $\frac{T_{max} - T_{min}}{2^N - 1}$  +  $T_{min} = 17767 * \frac{1200°C - (-100°C)}{2^{16} - 1} + (-100°C)$ = 252.44 °C

### Example 4:

The analog mode is set to Voltage output 0 - 5 V. The resolution is 16 bit. The digital value written over IO-Link is  $8000_{\text{nex}} = 32768$ . Output voltage [V] = PortValue  $*\frac{V_{\text{max}} - V_{\text{min}}}{2^{N} - 1} + V_{\text{min}} = 32768 * \frac{5 - 0}{2^{16} - 1} + 0 = 2.5V$ 

#### 3.10. Dimensioned data format In case of dimensioned format, the voltage, current or temperature will be represented in mV, μA or °C (in 0.1 °C step). In this case the resolution and process data alignment settings do not influence the data. It must be always handled as a right aligned data, and as a 16 bit value.

Voltage signal (0V-10V, 5V - 10V, -10V - +10V, 0V - 5V, -5V - +5V):

In case of positive numbers (MSB = 0):

Input voltage  $[V] = \frac{PortValue}{1000}$ 

In case of negative numbers (MSB = 1):

Input voltage [V] =  $\frac{\text{PortValue} - 65536}{1000}$ 

### Current signal (0-20mA, 4-20mA):

Input current  $[mA] = \frac{PortValue}{1000}$ 

### Pt100, Pt1000, Typ J, Typ K:

In case of positive numbers (MSB = 0):

Temperature [°C] =  $\frac{\text{PortValue}}{10}$ 

In case of negative numbers (MSB = 1):

Temperature [°C] =  $\frac{\text{PortValue} - 65536}{10}$ 

Where: PortValue is the digitalized value of the input signal.

Example 1:

The analog mode is set to 0-10V input. The digitalized value read over IO-Link is 15BA<sub>hex</sub> = 5562.

In case of voltage input, the dimensioned value has the dimension of mV.

Input voltage [V] =  $\frac{\text{PortValue}}{1000} = \frac{5562}{1000} = 5.562V$ 

### Example 2:

The analog mode is set to 0-10V input. The digitalized value read over IO-Link is  $EC78_{hex} = 60536$ .

In case of voltage input, the dimensioned value has the dimension of mV.

Input voltage [V] =  $\frac{\text{PortValue} - 65536}{1000} = \frac{60536 - 65536}{1000} = -5.000V$ 

### Example 3:

The analog mode is set to 4-20 mA input. The digitalized value read over IO-Link is  $3A9F_{hex} = 15007$ .

In case of current input, the dimensioned value has the dimension of µA.

Input current [mA] =  $\frac{\text{PortValue}}{1000} = \frac{15007}{1000} = 15.007 \text{ mA}$ 

### Example 4:

The analog mode is set to TypJ Thermocouple. The digitalized value read over IO-Link is 06F1hex = 1777

In case of Thermocouple input, the dimensioned value has the dimension of 0.1 °C

Temperature [°C] =  $\frac{\text{PortValue}}{10} = \frac{1777}{10} = 177.7 \text{ °C}$ 

### 4.1. IO-Link Data

BNI IOL-717-002-E023								
Data transmission rate	COM2 (38,4 kBaud)							
Minimal cycle time	10 ms	10 ms						
Process data lenght	3 Byte input							
IO-Link Revision	1.1	1.0						
Frame typ	2.V	1						
Process data cycle time*	10 ms	40 ms						

BNI IOL-725-002-E023								
Data transmission rate	COM2 (38,4 kBaud)							
Minimal cycle time	10 ms							
Process data lenght	2 Byte output							
IO-Link Revision	1.1	1.0						
Frame typ	2.V	1						
Process data cycle time*	10 ms	20 ms						

BNI IOL-730-002-E023					
Data transmission rate	COM2 (38,4 kBaud)				
Minimal cycle time	10 ms				
Process data lenght	3 Byte input, 2 Byte output				
IO-Link Revision	1.1	1.0			
Frame typ	2.V	1			
Process data cycle time*	10 ms	60 ms			

BNI IOL-740-002-E023								
Data transmission rate	COM2 (38,4 kBaud)							
Minimal cycle time	10 ms							
Process data lenght	3 Byte input							
IO-Link Revision	1.1	1.0						
Frame typ	2.V	1						
Process data cycle time*	10 ms	40 ms						

\* by min. cycle time

# 4.2. Prozess data / BNI IOL-717-002-E023 / BNI IOL-730-002-E023 / BNI IOL-740-002-E023 / Input data

Byte	0											1				
Bit	7	6	5	4	3	2	1	0	7	6	5	4	3	2	1	0
Description							An	alog i	nput v	value						

Byte	2								
Bit	7	6	5	4	3	2	1	0	
Description	·	ı	Switch point 2**	Switch point 1**	·	Wire break*	Underflow	Overflow	

Overflow: This bit indicates when the measured signal is higher than the selected range Underflow: This bit indicates when the measured signal is lower than the selected range Wire break: This bit indicates wirebreak condition of the analog port in case of thermocouple input.

Switch point: The switch point bits show a switch point overrun. The switch point can be configured by parameter. (see "Switch point Enable", "Switch point 1" and "Switch point 2")

\*Only in case of BNI IOL-730-002-E023 and BNI IOL-740-002-E023 \*\*Only in case of BNI IOL-717-002-E023, BNI IOL-730-002-E023 and BNI IOL-740-002-E023

### 4.3. Prozess data / BNI IOL-725-002-E023 / BNI IOL-730-002-E023

### Output data



### 4.4. Parameter data / Request data

	DPP	ISDU					
	Index	Index	Sub- Index	Object name	Length	Range	Default value
	07hex			Vendor ID	2 Byte		0378
	08hex				2 Dyte		037 Ohex
	09hex						050207 <sub>hex</sub>
	0Ahex			Device ID	3 Byte		050208 <sub>hex</sub> 05020A <sub>hex</sub>
	0Bhex						050209 <sub>hex</sub>
		10hex	0	Vendor name	7 Byte		BALLUFF
Identification data		11hex	0	Vendor text	15 Byte		www.balluff.com
	12he 13he 14he	12hex	0	Product name	20 Byte	read only	BNI IOL-717-002-E023 BNI IOL-725-002-E023 BNI IOL-730-002-E023 BNI IOL-740-002-E023
		13hex	0	Product ID	7 Byte		BNI00C9 BNI00C8 BNI00C6 BNI00C7
		14hex	0	Product text			Converter Analog Input Converter Analog Output Univers. Analog converter Converter Temperature
		15hex	0	Serial Nr	16 Byte		
		16hex	0	Hardware Revision	1 Byte		
		17hex	0	Firmware Revision			
		18hex	0	Application Specific Tag	32 bytes	read / write	O <sub>hex</sub>

	DPP	ISDU					
	Index	Index	Sub- Index	Object name	Length	Range	Default value
		52hex	0 1-5	Device Temperature	5 Byte	read only	
		54hex	0	Serial number	16 Byte		16x 30 <sub>hex</sub>
	57 <sub>hex</sub> 0		Operating hours	4 Byte	read only		
		58 <sub>hex</sub>	0	Boot counter	4 Byte	read only	
		59hex	0	Process data alignment	1 Byte	01	0
		F0hex	0	Analog mode	1 Byte	0 <sub>hex</sub> -A <sub>hex</sub>	FF <sub>hex</sub>
data		F1hex	0	Resolution	1 Byte	03	0
meter		F2hex	0	Pin assignment*	1 Byte	03	0
Para		F3hex	0	Pt100/ Pt1000 mode**	1 Byte	03	2
		F5hex	0	Process data format	1 Byte	02	0
		F6hex	0	Switch Point 1****	2 bytes	0 <sub>hex</sub> - FFFF <sub>hex</sub>	0
		F7hex	0	Switch Point 2****	2 bytes	0 <sub>hex</sub> - FFFF <sub>hex</sub>	0
		F8hex	0 1-2	Switch Point Enable****	1 Byte	02	0
		F9	0	Thermocouple grounding**	1 Byte	01	
		FAhex	0	Fault state outputs***	1 Byte	03	0

\*Not implemented in case of BNI IOL-740-002-E023 \*\* Only in case of modules with Pt100/Pt1000 function \*\*\* Only in case of modules with output \*\*\*\*Only in case of modules with input

Device Temperature	The device measures its temperature during it is powered. The device stores the minimum and maximum temperature values measured during life-time and since last start-up.					
J∠nex	The tempera	ture value is stored as a signed 8 bit integer, with 1 $^{\circ}\mathrm{C}$	resolution.			
	For example: $1E_{hex} = 30_{dec} = 30 \text{ °C}$ $FD_{hex} = -3_{dec} = -3 \text{ °C}$					
	Subindex	Data				
	0	All values				
	1	Actual device temperature				
	2	Maximum device temperature since last power-on				
	3	Minimum device temperature since last power-on				
	4	Maximum temperature lifetime				
	5	Minimum temperature lifetime				
Setting the serial number 54 <sub>hex</sub>	The serial nu In order to us parameter. This prevents	mber has a default value of 16x 00 <sub>nex</sub> . The "Identity" master validation mode, a serial numb a a device from connecting to the wrong master port	er can be set using this			
	Note It is recommended to set a unique serial number for each device, and use the "Indentity" master validation mode.					
Operating hours 57 <sub>hex</sub>	The operating device.	The operating hours counter counts the number of usage hours during the lifetime of the device.				
Boot counter 58hex	The boot cou	nter counts the number of start-up.				

Process The analog values are sent as a 16 bit values over the IO-Link in process data. In case of 10, 12 or 14 bit resolution the analog value is padded with zeros in order to fill the 16 bit data alignment in the process data. The justification of the 10, 12 or 14 bit value can be set in Process data alignment ISDU register. 59hex

0 = Left justified

1 = Right justified

Analog values in process data in case of left justification for different resolutions.

Byte		0						1								
Bit	7	6	5	4	3	2	1	0	7	6	5	4	3	2	1	0
	MSB	10 bit analog value								LSB						
	MSB	on Signal of the state of the								LSB						
	MSB	14 bit analog value ຫຼື														
	MSB						16	bit ana	log va	lue						LSB

Analog values in process data in case of right justification for different resolutions.

Byte	0										1					
Bit	7	6	5	4	3	2	1	0	7	6	5	4	3	2	1	0
							MSB			10	bit ana	alog va	lue			LSB
					MSB	12 bit analog value							LSB			
			MSB			14 bit analog value							LSB			
	MSB						16	bit ana	log va	lue						LSB



The process data alignment does not have effect in case of dimensioned data format

Analog mode F0hex

The mode of the analog ports can be set with this ISDU register. This ISDU can be written with different values depending on the Analog Converter Variant.

BNI IOL-717-002-E023:

- 00<sub>hex</sub> = Voltage input, 0V 10V
- 01<sub>hex</sub> = Current input, 4mA 20 mA
- $02_{hex}$  = Voltage input, 5V 10V
- $03_{hex}$  = Voltage input, -10V 10V
- $04_{hex}$  = Voltage input, 0V 5V
- 05<sub>hex</sub> = Current input, 0mA 20 mA 06<sub>hex</sub> = Voltage input, -5V - +5V
- $07_{hex} = Pt100$  $08_{hex} = Pt1000$
- FF<sub>hex</sub> = Port is switched off

### BNI IOL-725-002-E023:

 $\begin{array}{l} 00_{\text{hex}} = \text{Voltage output, 0V - 10V} \\ 01_{\text{hex}} = \text{Current output, 4mA - 20 mA} \\ 02_{\text{hex}} = \text{Voltage output, 5V - 10V} \\ 03_{\text{hex}} = \text{Voltage output, -10V - 10V} \\ 04_{\text{hex}} = \text{Voltage output, 0V - 5V} \\ 05_{\text{hex}} = \text{Current output, 0mA - 20 mA} \\ 06_{\text{hex}} = \text{Voltage output, -5V - +5V} \\ \text{FF}_{\text{hex}} = \text{Port is switched off} \end{array}$ 

### BNI IOL-730-002-E023:

- $00_{hex} = Voltage input/output, 0V 10V$   $01_{hex} = Current input/output, 4mA - 20 mA$   $02_{hex} = Voltage input/output, 5V - 10V$   $03_{hex} = Voltage input/output, -10V - 10V$   $04_{hex} = Voltage input/output, 0V - 5V$   $05_{hex} = Current input/output, 0mA - 20 mA$   $06_{hex} = Voltage input/output, -5V - +5V$   $07_{hex} = Pt100$   $08_{hex} = Pt1000$   $09_{hex} = Type J thermocouple$   $0A_{hex} = Type K thermocouple$  $FF_{hex} = Port is switched off$
- liox

### BNI IOL-740-002-E023:

 $\begin{array}{l} 07_{\text{hex}} = Pt100\\ 08_{\text{hex}} = Pt1000\\ 09_{\text{hex}} = Type \ J \ thermocouple\\ 0A_{\text{hex}} = Type \ K \ thermocouple\\ FF_{\text{hex}} = Port \ is \ switched \ off \end{array}$ 

In case of BNI IOL-730-002-E023, when voltage or current type analog mode has been selected, the direction of the signal (input or output) will be determined by the Pin Assignment ISDU ( $F2_{hex}$ )

### Attention!

 $\Delta$ 

Changing the analog mode of the port to voltage or current input, +24V will be switched between pin1 and pin3, in order to supply the analog sensor. Be sure, that no Pt100 or Pt1000 sensor is connected to the analog port. The +24V supply voltage can damage the RTD sensor.

Resolution F1hex

The resolution of the analog value can be set with this ISDU register.

0 = 16 bit resolution

- 1 = 14 bit resolution
- 2 = 12 bit resolution
- 3 = 10 bit resolution

### Note i

The resolution does not have effect in case of dimensioned data format.

Pin assignment F2hex

In case of voltage or current signal the source pin (pin 2 or pin 4) can be selected with an ISDU.

### BNI IOI -717-002-E023-

Value	Function	Input signal+	Input signal-		
0	Pin4 input	Pin4	Pin3		
2	Pin2 input	Pin2	Pin3		

### BNI IOL-725-002-E023:

Value	Function	Output signal+	Output signal-
1	Pin4 output	Pin4	Pin2
3	Pin2 output	Pin2	Pin4

### BNI IOL-730-002-E023:

Value	Function	Input/output signal+	Input/output signal-		
0	Pin4 input	Pin4	Pin3		
1	Pin4 output	Pin4	Pin2		
2	Pin2 input	Pin2	Pin3		
3	Pin2 output	Pin2	Pin4		

### BNI IOL-740-002-E023:

This ISDU is not implemented, because in case of Pt100, Pt1000 and thermocouple the pin-out of the analog port is fixed.

Pt100/Pt1000 mode F3hex	The measurement method for the Pt sensor can be set with this ISDU register. This ISDU is not implemented in case of BNI IOL-725-002-E023.
	0 = 2 wire measurement 1 = 3 wire measurement 2 = 4 wire measurement
Process data format F5hex	The analog value can be represented in different formats in the process data. 0 = Signed 1 = Unsigned 2 = Dimensioned (mV, μA, x0.1 °C)
Switch point 1, F6hex Switch point 2, F7hex	Two switch points can be set. When the analog value is greater than the value of the switch point, the corresponding bit in the process data will be set. Each switch point ISDU register is 2 byte long.

Subindex 0:

Byte	0	1
	Switch Doint V	

In order to avoid flickering of the switch point bit in process data, the switch point is evaluated with hysteresis. The hysteresis for different input types are listed in the table above.

Input type	Hysteresis
Voltage	5 mV
Current	10 µA
Temperature	1 °C



The switch point value must be set according to the resolution and process data format. The switch point value is always right justified.

Switch point enable F8hex

Each switching point can be enabled or disabled. When a switch point is disabled, the corresponding bit in the process data will be set to 0. When switch point is enabled, the analog value will be compared to the switch point value, and the corresponding bit will be set in the process data according to the result of the comparison.

2 3

#### 4 **IO-Link Interface**

Thermocouple grounding F9 <sub>hex</sub>	There are 7XX-002- measuren measure f	here are three types of thermocouples: ungrounded, grounded and exposed. The BNI IOL- (X-002-E023 is able to measure all of them, but in case of grounded thermocouple the easurement range is reduced. The thermocouple type must be set in the ISDU in order to easure the thermocouple correct.						
	0 = Ungro 1 = Groun	) = Ungrounded thermocouple I = Grounded thermocouple						
	The ungrounded measurement mode should be selected in case of ungrounded and in ca exposed thermocouple. In case of exposed thermocouple the hot junction must not have galvanic connection to conductive surfaces. In case of grounded thermocouple the sheath of the thermocouple must be connected to t ground.							
Fault state outputs FA <sub>hex</sub>	In case of analog outputs (BNI IOL-725-002-E023 or BNI IOL-730-002-E023 configured as output) a fault state value can be set with this ISDU. When the IO-Link communication is lost, the Master sets the PDO Valid (process data output valid) flag to inactive, the Analog Convert will drive its outputs according to the fault state settings.							
	Value	Output state in case of fault state						
	0	Output will be set to minimal value according to the selected output signal range						
	1	Output will be set to the middle value according to the selected output signal range						

Output will be set to maximal value according to the selected output signal range

The last valid output value will be kept.

### 4.5. Error

Error Code	Description
0x8011	Index not available
0x8012	Subindex not available
0x8023	Access Denied
0x8030	Parameter Value out of Range
0x8033	Parameter length overrun
0x8034	Parameter length underrun

### 4.6. Events

IO-Link Revision 1.0				
Event Code	Description			
0x4210	Device temperature over-run			
0x4220	Device temperature under-run			
0x5112	Low sensor voltage (US)			
0x5114	Low actuator voltage (UA)			
0x5410	Short circuit on pin1			
0x8C00	Internal error			
0x8C20	Measurement value is out of range			
0x8DF3	Thermocouple wire break detected			
IO-Link Revision 1.1				
Event Code	Description			
0x4210	Device temperature over-run			
0x4220	Device temperature under-run			
0x5111	Low sensor voltage (US)			
0x5112	Low actuator voltage (UA)			
0x7700	Thermocouple wire break detected			
0x7710	Short circuit on pin1			
0x8C00	Internal error			
0x8C20	Measurement value is out of range			

### Note The e

The events listed above are available in the BNI IOL-730-002-E023. This variant implements all analog functionality. The versions, which do not support all functionality, implement only the subset of the events.

# Note

The Low actuator voltage event will be sent in case of BNI IOL-730-002-E023 only, when the analog port is configured as an output.

### 5 Technical Data

### 5.1. Dimensions



### 5.2. Mechanical Hou Data IO-I

Housing material	Stainless steel housing
IO-Link-Port	M12, A-coded, male,
Analog Ports	M12, female, 5-poles
Enclosure rating per IEC 60529	IP67 (only when plugged in and threaded in)
Weight	ca. 105 g
Dimensions (L × D in mm)	135.5 x 18

### 5.3. Electrical Data

Operating conditions	18 30,2 V DC, per EN 61131-2	
Ripple	< 1 %	
Current draw without load	≤ 60 mA	
Load current (Analog port Pin1) BNI IOL-717-002-E023 BNI IOL-740-002-E023 BNI IOL-730-002-E023 configured as analog input	≤ 200 mA	
Load current (Analog port Pin1) BNI IOL-725-002-E023 BNI IOL-730-002-E023 configured as analog output	≤ 1.4 A	
Voltage input measuring error	<±0.1% full-scale, <2 mV, which is greater	
Current input measuring error	<±0.1% full-scale, <4 uA, which is greater	
Pt100, Pt1000 input measuring error	<±0.2% full-scale, <0.2 °C, which is greater	
TypJ thermocouple measuring error	<0.5 °C	
TypK thermocouple measuring error	-180 °C100 °C: <1ັC -100 °C - +1370 °C: <0.5 °C	
Voltage output accuracy	no output load: <±0.1% full-scale, <5 mV, which is greater	
Current output accuracy	<±0.2% full-scale, <10 uA, which is greater	
Voltage output load	>10 kOhm	
Current output load	<500 Ohm	
Temperature coefficient	<±0.01% / °C	
	5 °C 170 °C	
Storage temperature	-25 °C +70 °C	
Storage temperature	-23 0 +10 0	

# 5.4. Operating conditions

### 5 Technical Data

### 5.5. LED indicators

### Status LEDs

	Indicator	Function
IO-Link communication	Green	No communication
Green, negative pulsed		Communication OK
Power supply LED	Green	US and UA power supply are OK
	Green, slow flashing (2 Hz)	Power supply UA is not OK
	Green, fast flashing (4 Hz)	Power supply US is not OK
	Red, fast flashing (4 Hz)	Short circuit on Pin1 of analog connector
	Red	Internal error
Off		Power supply US is <15V



i

The power supply LED shows the state of the UA power supply only in case of BNI IOL-725-002-E023 and BNI IOL-730-002-E023. In case of BNI IOL-730-002-E023 the LED indicates the state of UA power supply only, when the analog port is configured as an output.

#### Appendix 6

6.1. Type designation code	Balluff Network Interface IO-Link Interface 717 = Analog input (voltage, current, Pt100, Pt 725 = Analog output (voltage, current) 730 = All analog signals 740 = Thermocouple input (TypJ, TypK) Versions 002 = Base version, IO-Link V1.1 Mechanical design E023 = Stainless steel housing	BNI IOL-7xx-002-E023
6.2. Order information	Product ordering code	Order code
	BNI IOL-717-002-E023	BNI00C9
	BNI IOL-725-002-E023	BNI00C8
	BNI IOL-730-002-E023	BNI00C6
	BNI IOL-740-002-E023	BNI00C7

# www.balluff.com

Balluff GmbH Schurwaldstrasse 9 73765 Neuhausen a.d.F. Germany Tel. +49 7158 173-0 Fax +49 7158 5010 balluff@balluff.de



### **Headquarters**

### Germany

Balluff GmbH Schurwaldstrasse 9 73765 Neuhausen a.d.F. Phone +49 7158 173-0 Fax +49 7158 5010 balluff@balluff.de

### Eastern Europe Service Center

### Poland

Balluff Sp. z o.o. UI. Graniczna 21A 54-516 Wrocław Phone +48 71 382 09 02 service.pl@balluff.pl

### **DACH Service Center**

Germany

Balluff GmbH Schurwaldstrasse 9 73765 Neuhausen a.d.F. Phone +49 7158 173-370 service.de@balluff.de

### Americas Service Center

## USA

Balluff Inc. 8125 Holton Drive Florence, KY 41042 Toll-free +1 800 543 8390 Fax +1 859 727 4823 service.us@balluff.com

# Southern Europe Service Center

## Italy

Balluff Automation S.R.L. Corso Cuneo 15 10078 Venaria Reale (Torino) Phone +39 0113150711 service.it@balluff.it

### Asia Pacific Service Center

### **Greater China**

Balluff Automation (Shanghai) Co., Ltd. No. 800 Chengshan Rd, 8F, Building A, Yunding International Commercial Plaza 200125, Pudong, Shanghai Phone +86 400 820 0016 Fax +86 400 920 2622 service.cn@balluff.com.cn