MAINTENANCE



Contents of this Chapter

Maintenance
Project Backup
Check Operating Environment
Check Operating Voltage
Check Status Indicators
Check Physical Conditions
Run Tests under System Setup Screens
Check Memory Usage
Check/Adjust Display Brightness
Check Error Log
Adjust Touch Panel
Cleaning the Display Screen
Check Project Functionality
Checks from C-more Programming Software
Maintenance Notes:

MAINTENANCE



Although the **C-more** touch panels require very little maintenance, setting up a routine maintenance schedule will ensure the longevity of the product in your application. The following are some suggestions of items to include in a preventive maintenance list or schedule. Most of these items should be scheduled quarterly or semi-annually.

PROJECT BACKUP

During routine preventive maintenance is a good time to make sure that there is an up-to date backup of the application project. Although the *C-more* touch panel has the ability to upload the complete project from a panel through the programming software, insurance is warranted just in case the worse case scenario happens and the entire touch panel is destroyed.

CHECK OPERATING ENVIRONMENT

- Make sure the touch panel is operating in the proper temperature range: 0 to 50 °C (32 to 122 °F).
- Make sure the touch panel is operating within the specified humidity range: (5 95% RH, non-condensing).

CHECK OPERATING VOLTAGE

• Check the DC input voltage that is powering the touch panel to make sure it is within 10.2-26.4 VDC.

CHECK STATUS INDICATORS

• During routine maintenance is a good time to take a quick look at the status indicators on the front and rear of the touch panel. The Power LED (PWR) indicator should be on and there should be activity on the TxD and RxD LED indicators when connected serially to a PLC or control device. Check the status of the CPU LED and compare it to the chart shown in the illustration below. Any indication of the CPU LED other than a solid green shows there is a possible problem, and the condition needs to be corrected.





NOTE: CM5-T4W doesn't have a User Defined LED or Power LED.



Rear View

CHECK PHYSICAL CONDITIONS

- Make sure that harmful chemicals are not being used around the panel. Look for any deterioration of the touch panel's bezel and front display area.
- Check the mounting gasket to make sure it is sealing properly and has not deteriorated. Replace the mounting gasket if there are any signs of deterioration, or if there is any evidence that moisture/liquids have penetrated to the inside of the enclosure where the panel is mounted. Information on a replacement gaskets can be found in **Chapter 9: Replacement Parts**.
- Check to make sure that none of the cooling vents around the inside section of the touch panel are clogged with dust or debris. Also make sure that there is clearance around the touch panel as shown in **Chapter 4: Installation and Wiring**.

RUN TESTS UNDER SYSTEM SETUP SCREENS

• Use the touch panel's System Setup Screens to test the touch screen, display, communication ports, beeper and audio output (only with external amplifier and speaker(s) connected). See **Chapter 5: System Setup Screens** for additional details for the Test

Test Touch Panel - allows the user to check the analog touch function of the screen by drawing free hand lines and shapes across the entire touch area. The display will retain the lines where the screen has been touched until the **Close** button is pressed.

Test Menu						
Test Touch Panel	Test Beep/ USB Audio	Test Serial Port	Test Ethernet Port			
Test Display	Test User LED					
			Close			

Test Display - used to test the display and color rendition. A test pattern will first show both the primary colors and a gray scale. If the touch screen is not pressed within a few seconds, the display will go into alternating color sweeps across the screen until the panel is pressed again. If the screen is pressed when the test pattern first appears, it will stay in this mode until the **Close** button is pressed.

Test Serial Port - used to test the functionality of the 15-pin PLC communication serial port, the 3-wire terminal block RS-485 port, the RJ12 RS-232 port. A loop-back connector can be fabricated and used on the serial ports to test the RS-232 or RS-422/485 communications for the TxD and RxD signals and also the RTS and CTS signals if applicable. The **Test Serial Port** setup screens and **Chapter 5** show pin-outs for the RS-232 and RS-422/485 loop-back connectors.

Test Ethernet Port - The Ethernet connection can also be tested for communications if it is at least connected to an Ethernet switch. If the touch panel is connected to a PLC, then an inquiry test can also be done to test the communications between the panel and the PLC. Press the **Cancel** button when finished to return to the **Test Menu**.

Test Beep/Sound - used to test the touch panel's internal beeper and also test the USB audio with a USB to Audio adapter and external amplifier and speaker(s) connected. Testing the audio output is done by playing an included internal WAV file. Press the **Close** button when finished to return to the **Test Menu**.

CHECK MEMORY USAGE

- A good time to check and record the touch panel's memory usage for future reference is during a routine maintenance schedule. The various memory devices being used by the panel are listed under the tab. This includes internal memory as well as any external memory device such as a USB pen drive or SD card memory. If no external memory device is inserted, it will not show up on the list.
- The memory usage can be viewed by use of the panel's **System Setup Screen's Main Menu**, and then selecting the Information button then the Memory tab. See Chapter 5: System Setup Screens for additional details on using the Memory tab.

CHECK/ADJUST DISPLAY BRIGHTNESS

 It is good practice to occasionally check the display brightness or contrast and adjust as required. This is done by using the Setting Screen in the System Setup Screens. See Chapter 5: System Setup Screens for additional details.

CHECK ERROR LOG

 Another good practice is to review the touch panel's Error Log. The log can be viewed by use of the panel's System Setup Screen's Main Menu, and then selecting the Information button. Look under the Error tab. See Chapter 5: System Setup Screens for additional details on using the Error tab, Appendix A: PLC Protocol Error Codes for a list of the error codes as they relate to the specific PLC that is being used with a description of the error, and Appendix B: Touch Panel Runtime Errors for a list of errors that may occur when the panel is in operation.

Adjust Touch Panel

It is recommended that a regularly scheduled maintenance program include adjusting the touch panel. The adjustment calibrates the touch area of the panel. The procedure should also be done anytime that it seems the touch area being pressed for an object is out of position by a small amount. The procedure is done by using the Setting Screen in the System Setup Screens and then selecting the Touch Panel button. See Chapter 5: System Setup Screens for additional details.

Information						
General	Mer	nory	Ethernet		Error	License
	Total	Use	d I	Free		
SDRAM:	428.7 MB	343.9 M	B 84.8	MB		
SRAM:	512.0 KB	124.0 K	B 388.0	KB		
Built-in Flash:	3.3 GB	1.4 G	B 1.9	GB		
SD1:	1.8 GB	1.2 M	B 1.8	GB		
						Clos

	10			1		9			
		16			2		10		
				-	3		11		
	▲ ▼			•	4		12		
					-		10		
			RED GREEN		5		13		
		RED		BLUE	6		14		
					7		15		
					8		16		
						_			
							ОК	Cancel	
				Inform	nation				
	General Memory Ethernet Error Lic				License				
No	Time		Code	Error	E				
1	02/21/23	05:04:29	PLC-00	1 PLC	Error Message BLC Communication Timeout (ETHERNET DEV/001 B				
2	02/21/23	05:04:19	PLC-00	1 PLC	PLC Communication Timeout (ETHERNET.DEV001.RE				
3	02/21/23	05:04:09	PLC-00	1 PLC	PLC Communication Timeout (ETHERNET, DEV001, RC				
4	02/21/23	05:03:59	PLC-00	1 PLC	PLC Communication Timeout (ETHERNET, DEV001, RC				
5	02/21/23	04:51:20	PLC-00	1 POR	PORT2 - PLC Communication Timeout (COM2,PORT2.				
6	02/21/23	04:51:19	PLC-00	1 POR	PORT2 - PLC Communication Timeout (COM2,PORT2				
7	02/21/23	04:51:19	PLC-00	1 POR	PORT1 - PLC Communication Timeout (COM1,PORT1				
8	02/21/23	04:51:18	PLC-00	1 POR	T2 - PLC C	commu	inication Timeor	It (COM2,PORT2	
9		04-54-47	DLC 00		PORT2 - PLC Communication Timeout (COM2,PORT2				
	02/21/23	04:51:17	PLC-00	1 POR	T2 - PLC C	commu	inication Timeor	IT (COM2, PORTZ	
10	02/21/23 02/21/23	04:51:17	PLC-00	1 POR 1 POR	T2 - PLC C T2 - PLC C	commi commi	inication Timeoi inication Timeoi	It (COM2,PORT2 It (COM2,PORT2	



Clear

Close



Adjust Display

CLEANING THE DISPLAY SCREEN

- The display screen should be cleaned periodically by wiping it with a lint free damp cloth using a mild soap solution. Dry the surface when finished with a lint free cloth. Do not clean with ammonia based products which are solvents and will damage the face of the panel.
- The longevity of the display can be increased by the use of a non-glare screen protector, p/n HMI-xW-COV, where x = touch panel screen size, 4, 7, 10, 12, 15 or 22. See Chapter 3: Accessories for additional information on the screen protectors.



• To prevent damage to the display screen, avoid touching the screen with sharp objects, striking the screen with a hard object, the use of abrasives near the screen, or using excessive force when pressing the touch screen.

CHECK PROJECT FUNCTIONALITY

- During routine maintenance is a good time to check the functionality of your application, making sure that various areas on different screens do what they were designed to do. An outline or specification for the application is a useful tool for testing the various aspects of your application. As a starting point, you may want to run through all the screens to make sure they are accessible.
- If there are any trouble-shooting procedures built into the touch panel application, now is a good time to also check these aids.

CHECKS FROM C-MORE PROGRAMMING SOFTWARE

- If you have a PC available with the *C-more* programming software, CM5-PGMSW, installed, and the PC is connected to the touch panel, there are checks you can make to the status of the touch panel by using the *Panel Information...* feature located under the *Main Menu* heading *Panel*. This includes the following:
 - · Connected panel details
 - · Memory availability and usage
 - Revisions

Connected Panel Info	_		×		
All	🗆 🎾 General				^
General	Panel				
	Panel Type:	CM5-T7W			
Memory	Panel Name:	CM5-T7W-025FFC			
Ethernet	Display:	7" TFT			
A Error List	Color Type:	64K			
	Resolution:	800x480			
	Project Boot Storage:	Built-in FLASH			
	Version				
	Hardware Version:	00-00-00			
	Boot Loader Version:	Ver00			
	OS Version:	Ver1.00 r763			
	Runtime Version:	Ver8.0			
	System Screen Version:	Ver1.0.25			
	Project				
	Project Name:	NewProject5			
		-			
					~
Refresh Interval: 3 sec	∨ Refresh		Close	Help	р

 Other functions that can be accessed from the programming software directly to the touch panel include: **Display Screen**, **Reboot**, **Adjust Clock**, **Memory Clear**, and **Update Firmware**. Additional information for these functions can be found in the **C-more** programming software online help file.

MAINTENANCE NOTES:

BLANK PAGE