



## Multi-Level Switch Kits

ASSEMBLY INSTRUCTIONS, KEEP FOR FUTURE REFERENCE.



1. Lay out the supplied components in the configuration that your application requires. A typical configuration is shown in the drawing on reverse side. Determine the lengths of the Connecting Tubes required for your application. NOTE: The tube end extends into the Union Fitting and End Cap 0.9 inches (22.9 mm).
2. Cut the Connecting (empty) Tube(s) to the lengths that your application requires. DO NOT CUT THE SWITCH CAPSULES (the short tubes with wires)! We suggest the use of a tubing cutter to get clean, square cuts.
3. De-burr the inside and outside of the cut ends of the tubes with a fine file, sandpaper, etc. Be sure to remove ALL sharp edges from the inside of the tubes to prevent damage to the insulation on the switch wires.
4. Trial assemble all of the tubes, floats and switch capsules using the supplied union fittings and end cap. The Upper Switch Capsule (L1) is the one with the Red wires and an inner tube. The wires from the Lower Switch Capsule (L2) must pass through the inner tube. Be sure that the Switch Capsules and Connecting Tubes bottom out in the union fittings and end cap. ONLY TIGHTEN THE UNIONS HAND TIGHT! Using a continuity indicator (light, buzzer, ohm meter, etc.), verify that the switch actuation levels (L1 and L2) are at the required levels and the switch action (normally open or normally closed) is correct for your application.



**BE CERTAIN THAT YOU HAVE THE SWITCH SET-UP THE WAY YOU REQUIRE BEFORE TIGHTENING ANY FITTINGS!**

5. Setting switch operation:

### Stainless Steel Floats:

NC - (dry position - switch will open on rising fluid level) round witness mark on end of the float AWAY from the large pipe fitting.

NO - (dry position - switch will close on rising fluid level) round witness mark on end of the float TOWARD the large pipe fitting.

### Buna-N Floats:

NC - (dry position - switch will open on rising fluid level) the 3 gray dots on the end of the float TOWARD the large pipe fitting.

NO - (dry position - switch will close on rising fluid level) the 3 gray dots on the end of the float AWAY from the large pipe fitting.

### Polypropylene Floats:

NC - (dry position - switch will open on rising fluid level) the 3 white dots on the end of the float TOWARD the large pipe fitting.

NO - (dry position - switch will close on rising fluid level) the 3 white dots on the end of the float AWAY from the large pipe fitting.

6. Re-test the electrical operation of both switches using a continuity indicator.
7. When the switch is completely set-up as you require, tighten the Union Fittings and End Cap, using 13/16" and 7/8" wrenches. Use the 13/16" to hold the body of the fitting and the 7/8" to tighten the nut. Tighten the nuts 1-1/4 turns past finger tight - no more!
8. Be sure to apply a suitable thread sealant to the pipe threads on the top fitting before installing the switch into your tank.

### WARNINGS:

- DO NOT cut or modify the switch capsules (the short tubes with the wires) in ANY way, except to cut the wires to the required length at installation.
- DO NOT exceed the Maximum Pressure and Temperature ratings, listed below:

Model	Max. Pressure	Max. Temperature
FLS-VK-300	200 PSIG (13.79 bar)	200°C (392°F)
FLS-VK-200	150 PSIG (10.34 bar)	105°C (221°F)
FLS-VK-100	100 PSIG (6.89 bar)	105°C (221°F)

- DO NOT exceed Current and Voltage ratings, listed below:

Watts	Voltage	Current (Amps) Resistive
60	240 VAC	0.4
60	120 VAC	0.5
60	120 VDC	0.2
60	24 VDC	0.5

*Note: These ratings are for resistive loads ONLY. For inductive loads, maximum life will be obtained with the use of appropriate transient suppression such as an MOV or TVS.*

**Maximum voltage rating = 240 VAC**

- Be sure that ALL fittings are assembled and tightened correctly.

**FOR TECHNICAL ASSISTANCE CALL 770-844-4200**

Parts List	
Qty.	Description
2	Mounting Tube
2	Connection Tubes
2	Switch Capsules
2	Floats
4	Compression Unions
1	End Cap

# Multi-Level Switch Kits

## TYPICAL SWITCH CONFIGURATION

