



P/N's BPAK-G/BPAK-B/BPAK-JIC BACK PANEL ADJUSTMENT KIT- Installation Instructions

This kit includes:


4- panel mounts 4- #10-32 phillips head screws
8- # M5 x 8mm set screws 1- allen wrench

Installation- To install, insert one set screw into one of the two channels molded into the panel mount (see photo). Start the set screw into the panel mount with a few turns of the allen wrench. Slide the panel-mount onto the integral t-track located in each corner of the enclosure. With the panel mount at the desired depth, use the allen wrench to tighten the set screw into the channel until the panel mount becomes snug. This will happen when the set screw tip is flush or extends past the bottom of the pad by about 1/16". Install second set screw in each panel mount, on the opposite side of the rail.

Note that this design supports the attachment of the panel mounts to the sub panel prior to installation into the enclosure. Just drop the assembly into the enclosure and tighten.

Integra Enclosures, Inc.

7750 Tyler Blvd.
Mentor, OH 44060
440-269-4966 fax 440-269-4977
www.integraenclosures.com
Rev: 1-12-2011



P/N's BPAK-G/BPAK-B/BPAK-JIC BACK PANEL ADJUSTMENT KIT- Installation Instructions

This kit includes:

4- panel mounts 4- #10-32 phillips head screws
8- # M5 x 8mm set screws 1- allen wrench

Installation- To install, insert one set screw into one of the two channels molded into the panel mount (see photo). Start the set screw into the panel mount with a few turns of the allen wrench. Slide the panel-mount onto the integral t-track located in each corner of the enclosure. With the panel mount at the desired depth, use the allen wrench to tighten the set screw into the channel until the panel mount becomes snug. This will happen when the set screw tip is flush or extends past the bottom of the pad by about 1/16". Install second set screw in each panel mount, on the opposite side of the rail.

Note that this design supports the attachment of the panel mounts to the sub panel prior to installation into the enclosure. Just drop the assembly into the enclosure and tighten.

Integra Enclosures, Inc.

7750 Tyler Blvd.
Mentor, OH 44060
440-269-4966 fax 440-269-4977
www.integraenclosures.com
Rev: 1-12-2011

