# PRITIS\_

# **PX-549 – Eight Inputs/ Eight Outputs 24VDC Discrete Terminal**

The PX-549 DC Input/Output Terminal provides eight 24VDC inputs and eight 24VDC outputs at 0.5A per point, reverse polarity protection and

Dolarity protection and LED status. Use with the Protos X<sup>™</sup> I/O System.



Protos X<sup>™</sup> is a trademark of Automationdirect.com Incorporated

PX-549 I/O General Specifications						
nputs/Outputs per Terminal		8 sinking inputs / 8 sourcing outputs				
Data Bytes Used		1-byte (inputs) / 1-byte (outputs)				
nput/Output Power Source		Requires external 24VDC power source				
Operating Voltage Rating		24VDC (-15%/+20%)				
Current Consumption (from I/O Bus)		Typ. 25mA				
Current Consumption (from Terminal Power Bus)		Typ. 15mA + load				
PX-549 Input Specifications						
Peak Voltage Rating			30VDC			
On Voltage Level			15 to 30 VDC			
Off Voltage Level			-3 to +5 VDC			
Vinimum On Current			2mA			
Maximum Off Current			40µA			
Current Consumption (from I/O Bus)			Typ. 3mA			
Dff/On Response			3ms			
On /Off Response			3ms			
PX-549 Output Specifications						
Aax. Load Current per Output		0.5A (Short Circuit Protected)				
On Voltage Drop		0.14VDC @ 2A				
Vaximum Leakage Current		5µA				
Vaximum Inrush Current		2A				
Maximum Short-circuit volta	age	45V				
₋oad Type	-	Resistive, inductive, lamp				
Reverse Voltage Protection		Yes				
Off/On Response		50µs				
On /Off Response		75µs				
PX-549 Terminal Specifications						
Electrical Isolation			500Vms (I/O bus/field potential)			
Heat Dissipation			1W max			
Adjacent Mounting on Bus Terminals v			Yes, DC only			
Adjacent Mounting on Bus Terminals without Power Contact			No			
Passes Terminal Bus Power			Yes			
Passes PE Bus			No			
Status Indicators			8 input and 8 output, indicates on			
General Specifications						
Operating Temperature	32° to 131°F (0° to 55°C)					
Storage Temperature	13° to 185°F (-25° to 85°C)					
Relative Humidity	5% to 95%, non-condensing					
Environment Air	No corrosive gases permitted					
Mounting/Orientation Restrictions	35mm DIN rail/None					
/ibration	conforms to EN 60068-2-6					
Shock	conforms to EN 60068-2-27, EN 60068-2-29					
Noise Immunity	conforms to EN 61000-6-2/ EN61000-6-4					
Protection Class	IP20					
eight 60g						
Dimensions (WxHxD)	12 x 100 x 68.8 mm (0.47 x 3.94 x 2.71 in)					
Agency Approvals	UL File No. E157382, CE					





Connect power supply common (-) to same common as terminal power bus

### MOUNTING

For system assembly, first attach a bus coupler by snapping onto 35mm DIN rail and securing into position using the DIN rail locking wheel (where applicable) located on the left side of the coupler. To add a bus terminal, insert unit onto right side of bus coupler using the tongue and groove at the top and bottom of the unit, pressing gently until it snaps onto the DIN rail. A proper connection cannot be made by sliding the units together on the DIN rail. When correctly installed, no significant gap can be seen between the attached units. Bus connection is made through the six slide contacts located on the upper right side of the units. Add up to 64 bus terminals per bus coupler, including a bus end terminal.

### REMOVAL

A locking mechanism prevents individual units from being pulled off. For bus terminal removal, pull the orange DIN rail release tab firmly to unlatch the unit from the rail. If attached to other terminal units, slide unit forward until released. For bus couplers with locking wheels, release the DIN rail locking wheel, then pull firmly on DIN rail release tab.

Insert unit using tongue and groove molded guide and press gently until it becomes firmly seated on DIN rail.

Where applicable, rotate Locking Wheel to lock Bus Coupler



molded guide

Where applicable, rotate Locking Wheel to unlock Bus Coupler



Firmly pull DIN Rail Release Tab to unlatch unit from rail.

### IMPORTANT

For complete assembly instructions and compatibility between terminals see the PX-USER-M manual available for free download at www.automationdirect.com.

### HOT SWAP NOT PERMITTED

Always remove power from the system before inserting or removing bus terminals or couplers as failure to do so could cause malfunction or damage to the terminals, couplers or other connected devices.

Document Name	Edition/Revision	Date
PX-549-DS	1st ED.	9/15/2014

Copyright 2014, AutomationDirect.com Incorporated/All Rights Reserved Worldwide.

### WARNING

To minimize the risk of potential safety problems, you should follow all applicable local and national codes that regulate the installation and operation of your equipment. These codes vary from area to area and it is your responsibility to determine which codes should be followed, and to verify that the equipment, installation, and operation are in compliance with the latest revision of these codes.

Equipment damage or serious injury to personnel can result from the failure to follow all applicable codes and standards. We do not guarantee the products described in this publication are suitable for your particular application, nor do we assume any responsibility for your product design, installation, or operation.

If you have any questions concerning the installation or operation of this equipment, or if you need additional information, please call Technical Support at 770-844-4200.

This publication is based on information that was available at the time it was printed. At AutomationDirect. com® we constantly strive to improve our products and services, so we reserve the right to make changes to the products and/or publications at any time without notice and without any obligation. This publication may also discuss features that may not be available in certain revisions of the product.

## WIRING CONNECTION

Wire connection is made through a spring clamp style terminal. This terminal is designed for a single-conductor solid or stranded wire. Wire connection is made by firmly pushing the screwdriver into the screwdriver slot, inserting the wire into the wire slot and removing the screwdriver, locking the wire into position.



Wiring Specifications				
Connection Type	Spring Clamp Terminals			
Wire Gauge / Wire Cross Section	28-14 AWG / 0.08 - 2.5mm <sup>2</sup>			
Screwdriver Width	2.5mm (0.10) such as our TW-SD-MSL-2			
Wire Stripping Length	8mm			

www.automationdirect.com